



Dunlop Flooring
380 Dohertys Road, Truganina VIC 3029
Tel 1800 622 293
dunlopflooring.com.au

VOC Content Calculation Certificate

Report Date: 26th September, 2024

Standard: SCAQMD Method 304-91 Determination of Volatile Organic Compound (VOC) in various materials as referenced by South Coast Air Quality Management Division.

Standard SCAQMD Method 304-91 Rule 1168	Dunlop Ultralay Vinyl Plank Adhesive
General purpose adhesives and sealants 50 grams per Litre	23 grams per Litre

Above results are based on SCAQMD METHOD 304-91 with the moisture content calculated from the formulation.
